Facility Well Name CHS Refinery #2 **UIC Permit #** KS-01-113-009 **Month** April **Year** 2021

Submitted 05/17/2021 **Approved** 05/20/2021 **KOLAR Document ID** 1572886

Class I-V Injection Well Monthly Monitoring

Summary of Monthly Report

Number of days injection occurred: 30

Barrels per Day Maximum: 51,429

			Annulus Pressure psig min 60		Injection Pressure		
	Injection Volume Barrels per Day	Injection Rate Barrels per Minute	Gauge psig	Cont. Record psig	Gauge psig	Cont. Record psig	Amount Added to Seal Pot
Monthly Average	9,986	6.94	102	101	2.1	1.5	
Monthly Maximum	21,139	14.69	110	109	3.0	3.0	
Monthly Minimum	5,348	3.71	98	97	2.0	1.1	
Monthly Total	299,574						

Summary of Continuous Recorder Data

Maximum Annulus Pressure psig	Minimum Annulus Pressure psig	Maximum Injection Pressure psig	Minimum Injection Pressure psig
117.89	95.58	15.81	1.07

Comments:

CHS Refinery #2 04/2021

Daily Recorder Data

Day	Time 24 hr	Injection Volume Barrels Per Day	Injection Rate Barrels Per Minute	Annulus Pressure (Gauge) psig	Annulus Pressure (Continuous Recorder) psig	Injection Pressure (Gauge) + / -	Injection Pressure (Continuous Recorder) + / -	Seal Pot Fluid Level inches	Type of Fluid Added to Seal Pot	Amount of Fluid Added to Seal Pot gallons	Initials of Collector of Field Recordings		
1	07:00	13,602.86	9.45	103	99.9	2	1.4	7			MW		
2	07:00	11,953.71	8.31	100	97.9	2	1.3	7			MH		
3	07:00	17,826.86	12.38	102	99.1	3	1.5	6			MH		
4	07:00	18,210.17	12.64	104	103.0	2	1.4	8			MH		
5	07:00	21,139.19	14.69	104	104.1	2	1.6	8			JC		
6	07:00	11,033.48	7.67	102	103.2	2	1.6	8			JC		
7	07:00	10,637.83	7.38	104	103.1	2	1.7	9			MH		
8	07:00	9,948.33	6.90	101	99.6	2	1.4	6			MH		
9	07:00	11,162.40	7.76	102	102.1	2	1.4	7			MB		
10	07:00	11,107.19	7.71	106	104.7	3	1.9	7			MB		
11	07:00	11,678.40	8.12	110	108.7	2	3.0	8			MB		
12	07:00	8,935.55	6.21	106	107.2	2	1.4	9			RM		
13	07:00	5,347.55	3.71	102	101.4	3	1.5	8			RM		
14	07:00	8,041.38	5.60	100	98.7	2	1.2	6			JC		
15	07:00	7,440.00	5.17	100	99.1	2	1.3	6			JC		
16	07:00	7,654.62	5.31	98	97.1	2	1.3	5			RM		
17	07:00	7,874.05	5.48	99	98.3	2	1.3	5			MB		
18	07:00	8,133.60	5.64	100	99.2	2	1.2	5			MB		
19	07:00	8,265.95	5.74	100	100.2	2	1.2	5			BF		
20	07:00	7,852.12	5.45	98	98.6	2	1.3	5			BF		
21	07:00	8,083.88	5.62	100	98.0	2	1.3	5			MB		
22	07:00	7,562.40	5.26	102	100.3	2	1.4	5			RM		
23	07:00	7,553.14	5.24	100	100.8	2	1.4	4			JC		
24	07:00	7,724.24	5.36	100	100.1	2	1.3	5			JC		
25	07:00	8,631.43	6.00	104	103.2	2	1.1	5			JC		
26	07:00	8,721.26	6.05	105	103.8	2	1.5	5			AS		
27	07:00	8,226.86	5.71	104	102.9	2	1.4	5			MH		
28	07:00	7,992.00	5.55	103	103.9	2	1.4	6			MB		
29	07:00	8,566.62	5.95	101	100.6	2	1.3	6			MB		
30	07:00	8,667.10	6.02	104	101.3	2	1.5	6			AS		
31													

CHS Refinery #2 04/2021

Weekly Injectate Samples

Kansas Lab Certificate Number E-10116

Week	**Temperature**		**pH**		**Chloride**				
	Degrees Fahrenheit	Date	Standard Units	Date	Cl concentration (mg/l)	Date Sample Collected	Date Sampl Analysed		
1	88.00	04/06/2021	7.56	04/06/2021	692.0	04/06/2021	04/26/2021		
2	87.00	04/13/2021	7.24	04/13/2021	693.0	04/13/2021	04/26/2021		
3	78.00	04/20/2021	7.18	04/20/2021	1,210.0	04/20/2021	04/26/2021		
4	76.50	04/27/2021	7.32	04/27/2021	894.0	04/27/2021	05/07/2021		
5									

No monthly injectate samples required.