Facility Well Name CHS Conway #2 **UIC Permit #** KS-01-113-014 **Month** January **Year** 2024

Submitted 02/16/2024 **Approved** 03/04/2024 **KOLAR Document ID** 1756026

Class I-V Injection Well Monthly Monitoring

Summary of Monthly Report

Number of days injection occurred: 16

Barrels per Day Maximum: 16,000

			Annulus Pressure psig min 60		Injection Pressure		
	Injection Volume Barrels per Day	Injection Rate Barrels per Minute	Gauge psig	Cont. Record psig	Gauge psig	Cont. Record psig	Amount Added to Seal Pot
Monthly Average	6,823	4.74	90	90	1.4	0.8	
Monthly Maximum	13,729	9.52	111	112	2.0	1.4	
Monthly Minimum	0	0.00	78	77	0.0	0.2	
Monthly Total	211,512						

Summary of Continuous Recorder Data

Maximum Annulus Pressure psig	Minimum Annulus Pressure psig	Maximum Injection Pressure psig	Minimum Injection Pressure psig
112.88	76.25	1.42	0.19

Comments:

CHS Conway #2 01/2024

Daily Recorder Data

Day	Time 24 hr	Injection Volume Barrels Per Day	Injection Rate Barrels Per Minute	Annulus Pressure (Gauge) psig	Annulus Pressure (Continuous Recorder) psig	Injection Pressure (Gauge) + / -	Injection Pressure (Continuous Recorder) + / -	Seal Pot Fluid Level inches	Type of Fluid Added to Seal Pot	Amount of Fluid Added to Seal Pot gallons	Initials of Collector of Field Recordings		
1	07:00	13,667.29	9.50	82	82.8	2	1.3	12			ML		
2	07:00	13,663.48	9.50	82	82.2	2	1.2	12			KJ		
3	07:00	13,671.95	9.50	82	82.4	2	1.3	12			KJ		
4	07:00	13,696.93	9.50	82	82.3	2	1.4	12			KJ		
5	07:00	13,685.86	9.50	82	80.6	2	1.3	12			KJ		
6	07:00	13,697.83	9.52	83	83.2	2	1.4	12			SS		
7	07:00	13,691.19	9.50	89	89.4	2	1.3	12			SS		
8	07:00	13,691.90	9.50	86	86.6	2	1.4	12			KJ		
9	07:00	13,691.17	9.50	88	89.3	2	1.4	12			KJ		
10	07:00	13,696.60	9.50	90	90.6	2	1.3	12			KJ		
11	07:00	13,697.48	9.52	88	87.6	2	1.3	12			KJ		
12	07:00	13,698.05	9.52	100	98.8	2	1.3	12			KJ		
13	07:00	13,729.05	9.52	102	102.8	2	1.2	12			GE		
14	07:00	13,081.93	9.10	111	111.6	2	1.3	12			SS		
15	07:00	12,873.00	8.93	110	111.1	2	1.3	12			KJ		
16	07:00	7,578.43	5.26	108	108.9	1	0.8	12			KJ		
17	07:00	0.00	0.00	110	108.6	1	0.5	12			KJ		
18	07:00	0.00	0.00	104	104.5	1	0.2	12			KJ		
19	07:00	0.00	0.00	96	96.3	1	0.2	12			KJ		
20	07:00	0.00	0.00	94	93.7	1	0.2	12			GE		
21	07:00	0.00	0.00	90	89.1	1	0.2	12			GE		
22	07:00	0.00	0.00	87	85.9	1	0.2	12			KJ		
23	07:00	0.00	0.00	84	82.9	1	0.3	12			KJ		
24	07:00	0.00	0.00	80	79.9	1	0.3	12			KJ		
25	07:00	0.00	0.00	78	77.4	1	0.3	12			KJ		
26	07:00	0.00	0.00	78	77.9	1	0.3	12			KJ		
27	07:00	0.00	0.00	84	85.8	0	0.3	12			MC		
28	07:00	0.00	0.00	84	83.4	0	0.3	12			MC		
29	07:00	0.00	0.00	81	80.8	0	0.3	12			KJ		
30	07:00	0.00	0.00	80	80.2	0	0.3	12			KJ		
31	07:00	0.00	0.00	80	80.2	1	0.3	12			KJ		

CHS Conway #2 01/2024

Weekly Injectate Samples

Kansas Lab Certificate Number E-10116

Week	**Temperature**		**pH**		**Chloride**				
	Degrees Fahrenheit	Date	Standard Units	Date	Cl concentration (mg/l)	Date Sample Collected	Date Sampl Analysed		
1	44.00	01/04/2024	5.90	01/04/2024	247,000.0	01/04/2024	02/01/2024		
2	45.00	01/10/2024	5.80	01/10/2024	225,000.0	01/10/2024	02/01/2024		
3	37.00	01/15/2024	6.20	01/15/2024	254,000.0	01/15/2024	02/01/2024		
4									
5									

No monthly injectate samples required.